



Reference Number: 24/01028/GDOPV

Proposal: Installation of 110 Solar PV panels on the roof of Melton Sports Village

Site: Melton Sports Village, Burton Road, Melton Mowbray, LE13 1DR

Applicant: Melton Borough Council

Planning Officer: Alex Coy

Report Author:	Alex Coy , Planning Policy Officer
Report Author Contact Details:	01664 502566 ACoy@melton.gov.uk
Chief Officer Responsible:	Sarah Legge , Assistant Director for Planning
Chief Officer Contact Details:	01664 502380 slegge@melton.gov.uk

Corporate Priority:	Delivering sustainable and inclusive growth in Melton
Relevant Ward Member(s):	Councillor Ian Atherton and Councillor Sharon Butcher (Melton Craven)
Date of consultation with Ward Member(s):	25 November 2024
Exempt Information:	No


Reason for Committee Determination: The prior approval notification is required to be considered by the Committee because the applicant is Melton Borough Council.

Web Link:

<https://pa.melton.gov.uk/online-applications/simpleSearchResults.do?action=firstPage>

What 3 words: <https://w3w.co/state.adding.grant>

Site Location Plan:



RECOMMENDATION(S)

1. It is recommended that no prior approval of the matters listed in Part 14, Class J are required (see section 8 below)

1 Executive Summary

- 1.1 This report addresses a 'Prior Approval Notification' for the installation of 110 Solar PV panels on the roof of Melton Sports Village. It is not a planning application as such; the legal basis for the Notification and the Council's responsibilities in this respect are explained below.
- 1.2 The Notification is required to be considered by the Committee because it is submitted by Melton Borough Council.

Main Report

2 The Site


- 2.1 The site is the Melton Sports Village located within Melton Mowbray and access via Burton Road. Adjacent to the site is Melton Sixth Form College and Birchwood School. The site is located outside the conservation area of Melton Mowbray.

3 Relevant Planning History

- 3.1 No relevant planning history

4 Proposal

- 4.1 The proposal is a prior approval notification for the installation of 110 Solar PV panels on a sloped section of the roof at Melton Sports Village. The prior approval notification is supported by block plans, elevations and specifications of the solar panels.
- 4.2 The proposal would see 110 Solar PV Panels installed on the south facing roof slope (see plan below). The panels would be fit close to the surface of the roof slope and measure 1.7m by 1.1m. The specification of the solar panels are Canadian Solar Inc., TOPHiKu6 445W.



5 Amendments

- 5.1 No amendments have been submitted to the initial proposal.

6 Planning Policy

- 6.1 The Council's role in the consideration of the prior approval notification is to establish whether all of the qualifying criteria have been met, and whether grounds exist to require a prior approval. It is a matter of fact whether it is permitted development and do not require a full planning application considering the legislation under Part 14, Class J of the General Permitted Development Order 2015 (as amended) as explored below.
- 6.2 For the reasons set out above, no consideration of Local Plan policies is necessary with prior approval notifications.

7 Consultation Responses

7.1 Summary of Technical Consultation Responses

- 7.1.1 Due to the nature of a prior notification, there is no requirement to consult with Statutory Consultees.

7.1.2 Summary of Representations

7.1.3 Ward Member(s)

- a) N/A

7.2 Response to Consultations and Representations

- 7.2.1 N/A

8 Planning Analysis

8.1 Main Considerations

- 8.1.1 The prior approval notification relates to the installation of solar PV panels on a non-domestic premises and therefore falls under Class J of Part 14 of the General Permitted Development Order (GPSO) 2015 (as amended). Each criteria of the regulations are responded to in bold.

8.2 Part 14 Class J Criteria

- 8.2.1 Class J – installation or alteration etc of solar equipment on non-domestic premises
Permitted development

J. The installation, alteration or replacement of—

- (a) microgeneration solar thermal equipment on a building;
(b) microgeneration solar PV equipment on a building; or
(c) other solar PV equipment on the roof of a building,
other than a dwellinghouse or a block of flats.

The proposal is for microgeneration solar PV equipment on a on a Leisure Centre building and therefore meets the criteria listed above.

- 8.2.2 Development not permitted

- 8.2.3 J.1 Development is not permitted by Class J if –

- (a) the solar PV equipment or solar thermal equipment would be installed on a pitched roof and would protrude more than 0.2 metres beyond the plane of the roof slope when measured from the perpendicular with the external surface of the roof slope;

The elevation plan demonstrates that the solar panels would protrude 131mm from the roof slope which is less than 0.2m.

- 8.2.4 b) the solar PV equipment or solar thermal equipment would be installed on a flat roof, where the highest part of the solar PV equipment would be higher than 1 metre above the highest part of the roof (excluding any chimney);

The solar panels would be installed on a sloped roof therefore this criteria is not relevant.

- 8.2.5 (c) the solar PV equipment or solar thermal equipment would be installed on a roof and within 1 metre of the external edge of that roof;

At all points of the installation the solar panels would be installed a distance greater than 1m of the external edge of the roof.

- 8.2.6 (e) the solar PV equipment or solar thermal equipment would be installed on a site designated as a scheduled monument; or

The site is not designated as a scheduled monument.

- 8.2.7 (f) the solar PV equipment or solar thermal equipment would be installed on a listed building or on a building within the curtilage of a listed building.

The site is not a listed building or within the curtilage of a listed building.

- 8.2.8 J.2 Development is not permitted by Class J(a) or (b) if –

- 8.2.9 (a) the solar PV equipment or solar thermal equipment would be installed on a wall and would protrude more than 0.2 metres beyond the plane of the wall when measured from the perpendicular with the external surface of the wall;

The solar panels would be installed on a sloped roof not a wall.

- 8.2.10 (b) the solar PV equipment or solar thermal equipment would be installed on a wall and within 1 metre of a junction of that wall with another wall or with the roof of the building; or

The solar panels would be installed on a sloped roof not a wall.

- 8.2.11 (c) in the case of a building on article 2(3) land, the solar PV equipment or solar thermal equipment would be installed on a wall which fronts a highway.

The building is not located within article 2(3) land (Conservation Area).

8.3 Part 14 Class J Conditions

- 8.3.1 J.4 — (1) Class J development is permitted subject to the following conditions—

- 8.3.2 (a) the solar PV equipment or solar thermal equipment must, so far as practicable, be sited so as to minimise its effect on the external appearance of the building and the amenity of the area; and

Due to the slope of the roof the proposed solar panels would be visible from the existing car park, however, due to the existing materials and finishes of the existing building, extent of coverage of the panels on this part of the roof and the minimal height panels (131mm), the panels are considered to conform with the external appearance of the building and would not impact on the amenity of the area. Especially given that solar panels are common place in the character of the area.

- 8.3.3 (b) the solar PV equipment or solar thermal equipment is removed as soon as reasonably practicable when no longer needed.

This is condition as part of the permitted development regulations therefore the development would be required to meet this to comply with conditions of Part 14 Class J.

- 8.3.4 (2) Class J(c) development is permitted subject to the condition that before beginning the development the developer must apply to the local planning authority for a determination as to whether the prior approval of the authority will be required as to the design or external appearance of the development, in particular the impact of glare on occupiers of neighbouring land, and the following sub-paragraphs apply in relation to that application.

This prior approval application meets the first part of this criteria, the design is considered not to impact the external appearance. The orientation of the solar panels with the angle facing the south is considered not to impact neighbourhood land which is a car park. In addition, the solar panels would have a 2mm heat strengthened glass front cover with anti-reflective coating to reduce the glare.

9 Conclusion & Reason for Recommendation

- 9.1 The proposed development accords with all of the criteria set by Part 14, Class J of the Planning (General Permitted Development) Order 2015 (as amended) and the matters subject of conditions specified by part J.4 of this legislation are not applicable to the circumstances of the case.
- 9.2 Therefore, it is recommended that a decision letter is issued to the applicant stating that prior approval is not required.

10 Planning Conditions

- 10.1 No additional planning conditions can be placed on this type of notification. The proposal is subject to the conditions stated within the Class J of the Planning (General Permitted Development) Order 2015 as detailed at part 8.3 of this report.

11 Financial Implications

- 11.1 There are no financial implications associated with this planning application.

Financial Implications reviewed by: N/A

12 Legal and Governance Implications

- 12.1 The Notification requires consideration by the Committee as it is submitted by the Council for its own development, (Constitution Chapter 2, Part 9, 'Planning Committee functions and procedures).

Legal Implications reviewed by: Deputy Monitoring Officer